

PRODUCT PERFORMANCE RATING

Document ID 1648202688-8e-23da3aa4

Issued on: 25 March 2022 - Délivré le : 25 mars 2022

This product is certified by Eurovent Certita Certification as mentioned on:
Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 94.01.198

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

Certification programmes / Programmes de certification

Product type / Type de produit

Model name / Nom du modèle

Range / Gamme

Participant / Titulaire

Brand / Marque

Air conditioners

Air to air, split, reversible (≤ 12 kW)

AOYG07KGCA/ASYG07KGTB

ASY**K

FUJITSU GENERAL (Euro) GmbH

FUJITSU

This performance certificate is delivered for the following project

Project Name	Project compagny	Project Reference	Project location
<i>Nom du projet</i>	<i>Nom de la société</i>	<i>Project Reference</i>	<i>Localisation du projet</i>
CoolBreeze	JABLOTRON LIVING TECHNOLOGY	CoolBreeze R32	Czechia

Document ID 1648202688-8e-23da3aa4

Issued on: 25 March 2022 - Délivré le : 25 mars 2022

This product is certified by Eurovent Certita Certification as mentioned on:
Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 94.01.198

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

FEATURE	VALUE	UNIT
Seasonal Efficiency In Cooling		
Pdesignc (Design Load Cooling)	2	kW
SEER (Seasonal Energy Efficiency Ratio)	8.52	
Qce (Annual electricity consumption for cooling)	82	kWh/annum
SEER Class (Seasonal Energy Efficiency Ratio Class)	A+++	
Heating Average Climate		
Pdesignh (Design load heating)	2.3	kW
SCOP (Reference SCOP)	5.12	
SCOP Class (Seasonal Coefficient Of Performance Class)	A+++	
Qhe (Annual electricity consumption for heating)	628	kWh/annum
Acoustic		
LW0 env (A-weighted sound level outdoor near the envelope for non ducted units)	61	dB(A)
LW1 env (A-weighted sound power level indoor unit 1 (non ducted))	54	dB(A)
Standard Cooling/Cooling PL Cond A		
Pc (Total Cooling Capacity)	2	kW
Pec (Effective Power Input for Cooling (for chilled water cooled Close Control units only)	0.4	kW
EER (Energy Efficiency Ratio)	5	
Cooling PL CondB		
Pc @ 30°C (Declared Cooling Capacity @ 30°C)	1.47	kW
EER @ 30°C (Declared Energy Efficiency @ 30°C)	6.9	
Cooling PL CondC		
Pc @ 25°C (Declared Cooling Capacity @ 25°C)	1.15	kW
EER @ 25°C (Declared Energy Efficiency @ 25°C)	10.85	
Cooling PL CondD		
Pc @ 20°C (Declared Cooling Capacity @ 20°C)	1.15	kW
EER @ 20°C (Declared Energy Efficiency @ 20°C)	13.45	
Standard Heating		
Ph (Heating Capacity)	2.5	kW
Peh (Net Electric Power Consumption for Heating Only application)	0.5	kW
COP (Coefficient Of Performance)	5	



Certificate N° 94.01.198

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com
Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

Heating PL CondA		
Ph @ -7°C (Declared Heating Capacity @ -7°C)	2.03	kW
COP @ -7°C (Declared Coefficient Of Performances @ -7°C)	3.35	
Heating PL CondB		
Ph @ +2°C (Declared Heating Capacity @ +2°C)	1.24	kW
COP @ 2°C (Declared Coefficient Of Performances @ 2°C)	5.15	
Heating PL CondC		
Ph @ +7°C (Declared Heating Capacity @ +7°C)	0.86	kW
COP @ +7°C (Declared Coefficient Of Performances @ +7°C)	6.35	
Heating PL CondD		
Ph @ +12°C (Declared Heating Capacity @ +12°C)	0.93	kW
COP @ +12°C (Declared Coefficient Of Performances @ +12°C)	8.31	
Bivalent Point		
Tbiv (Bivalent Temperature)	-7	°C
COP @ Tbiv (Declared coefficient of performances at bivalent temperature condition)	3.35	
Ph TBiv (Heating capacity at bivalent temperature)	2.03	kW
TOL Runing Test		
TOL (Operating LimitTemperature)	-15	°C
Ph E (Declared Heating Capacity @ TOL)	2.01	kW
COP E (Declared Coefficient Of Performances @ TOL)	2.72	
Poffc		
Poff (Power consumption in off mode)	1	W
Psb		
Psb (Power consumption in standby mode cooling (Paux, cooling))	1	W
Ptoc		
Pto (Power consumption in thermostat off mode)	5	W
Pck		
Pck (Power consumption of the crankcase heater)	0	W
General		
Inverter (Inverter (True/False))	true	
Main Power Supply (Voltage (V) - Phase - Frequency (Hz))	230-1-50	

PRODUCT PERFORMANCE RATING

Document ID 1648202688-8e-23da3aa4

Issued on: 25 March 2022 - Délivré le : 25 mars 2022

This product is certified by Eurovent Certita Certification as mentioned on:
Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :



Certificate N° 94.01.198

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

FEATURE	VALUE	UNIT
General		
Refrigerant	R32	
Refr. Line (Refrigerant Line. If possible)	5,0 m	m
Mounting (Mounting Type)	Wall mounted	